

# 2024 IECC

NBI has submitted proposals into the ICC process to advance the 2024 IECC. The proposed amendments cover a wide range of measures and improve the code by adding additional efficiency, clarifying requirements, and creating greater flexibility for code users and local jurisdictions. Learn more at [newbuildings.org/code\\_policy/2024-iecc-national-model-energy-code-base-codes](https://newbuildings.org/code_policy/2024-iecc-national-model-energy-code-base-codes).

## **Code Change Title:** Acceptance Testing in Alterations **CEPI-229-21**

**Summary:** Requires acceptance testing of existing HVAC, SHW or lighting systems that serve alterations.

### **Add new text as follows:**

**C503.4.2 Mechanical system acceptance testing.** Where an *alteration* requires compliance with Section C403 or any of its subsections, mechanical systems that serve the *alteration* shall comply with Sections C408.2.2, C408.2.3 and C408.2.5.

#### **Exceptions:**

1. Mechanical systems and service water heater systems in buildings where the total mechanical equipment capacity is less than 480,000 Btu/h (140.7 kW) cooling capacity and 600,000 Btu/h (175.8 kW) combined service water-heating and space-heating capacity.
2. Systems included in Section C403.5 that serve individual *dwelling units* and *sleeping units*.

### **Add new text as follows:**

**C503.5.1 Service hot water system acceptance testing.** Where an *alteration* requires compliance with Section C404 or any of its subsections, service hot water systems that serve the *alteration* shall comply with Sections C408.2.3 and C408.2.5.

#### **Exceptions:**

1. Service water heater systems in buildings where the total mechanical equipment capacity is less than 600,000 Btu/h (175.8 kW) combined service water-heating and space-heating capacity.
2. Systems included in Section C403.5 that serve individual *dwelling units* and *sleeping units*.

### **Add new text as follows:**

**C503.6.1 Lighting acceptance testing.** Where an *alteration* requires compliance with Section C405 or any of its subsections, lighting systems that serve the *alteration* shall comply with Section C408.3.

*The IECC does not require acceptance testing of the whole HVAC, hot water or lighting system when components of the system are replaced. Acceptance testing is even more critical in existing systems than new construction as they have had the opportunity for configurations and alterations to deviate from original installation. This proposal requires that the acceptance testing requirements of C408 that are relevant to existing buildings are applied to existing systems that undergo alteration.*