

# 2024 IECC

NBI has submitted proposals into the ICC process to advance the 2024 IECC. The proposed amendments cover a wide range of measures and improve the code by adding additional efficiency, clarifying requirements, and creating greater flexibility for code users and local jurisdictions. Learn more at [newbuildings.org/code\\_policy/2024-iecc-national-model-energy-code-base-codes](https://newbuildings.org/code_policy/2024-iecc-national-model-energy-code-base-codes).

## Code Change Title: Grid Optimal Credits CEPI-197-21

**Summary:** Establishes credits for buildings to shed load during peak demand hours.

### Add new definitions as follows:

**GRID-INTEGRATED CONTROL.** An automatic control that can receive, automatically respond to demand response requests from and send information back to a utility, electrical system operator, or third-party demand response program provider.

**BUILDING PEAK ELECTRIC DEMAND.** The annual highest whole-building electrical power demand, net of on-site renewables, measured in kW.

### Add new text as follows:

**C406.1 Additional energy efficiency credit requirements.** [no base text change]

12. Grid Integration Controls in accordance with Section C406.13.1 or Section C406.13.2.

### Revise tables as follows:

**Table C406.1(1) Additional Energy Efficiency Credits for Group B Occupants**

Climate Zone:	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
<u>C406.13.1 Grid integration controls</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>
<u>C406.13.2 Enhanced Grid integration controls</u>	<u>1</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>1</u>

**Table C406.1(2) Additional Energy Efficiency Credits for Group R and I Occupancies**

Climate Zone:	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
<u>C406.13.1 Grid integration controls</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>0</u>
<u>C406.13.2 Enhanced Grid integration controls</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>

**Table C406.1(3) Additional Energy Efficiency Credits for Group E Occupancies**

Climate Zone:	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
<u>C406.13.1 Grid integration controls</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>0</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>
<u>C406.13.2 Enhanced Grid integration controls</u>	<u>1</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>1</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>1</u>

**Table C406.1(4) Additional Energy Efficiency Credits for Group M Occupancies**

Climate Zone:	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
<u>C406.13.1 Grid integration controls</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>
<u>C406.13.2 Enhanced Grid integration controls</u>	<u>1</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>2</u>	<u>1</u>	<u>2</u>	<u>1</u>	<u>1</u>	<u>2</u>	<u>1</u>	<u>1</u>

**Table C406.1(5) Additional Energy Efficiency Credits for Other\* Occupancies**

Climate Zone:	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
<u>C406.13.1 Grid integration controls</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
<u>C406.13.2 Enhanced Grid integration controls</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>

**Revise text as follows:**

**C406.1.1 Tenant spaces.** Tenant spaces shall comply with sufficient options from Tables C406.1(1) through C406.1(5) to achieve a minimum number of 5 credits, where credits are selected from Section C406.2, C406.3, C406.4, C406.6, C406.7 or C406.10. Where the entire building complies using credits from Section C406.5, C406.8, ~~or C406.9,~~ or C406.13 tenant spaces shall be deemed to comply with this section.

**Add new text as follows:**

**C406.13.1 Grid integration controls.** The building shall contain *grid-integrated controls* that can automatically reduce *building peak electric demand* by an average of 10% over the single hour coincident with the *building peak electric demand*.

**C406.13.2 Enhanced Grid integration controls.** The building shall contain *grid-integrated controls* that can automatically reduce *building peak electric demand* by an average of 20% over the single hour coincident with the *building peak electric demand*.